

# RESNET One-Point Airtightness Test Form

Technician: \_\_\_\_\_

Date: \_\_\_\_\_

Building Address: \_\_\_\_\_

Building Address: \_\_\_\_\_

## Section A

---

Pre-Test Baseline Pressure Readings  
(include sign of reading)

_____	_____	_____	_____	_____
-------	-------	-------	-------	-------

Time Averaging Period (seconds)

_____
-------

Largest Baseline Reading

_____
-------

minus

Smallest Baseline Reading

_____
-------

Baseline Range

_____
-------

Check the appropriate accuracy level below, based on the size of the Baseline Range.

**Standard Accuracy Test** (Baseline Range less than 5.0 Pa)

**Reduced Level of Accuracy Test** (Baseline Range between 5.0 and 10.0 Pa)

**Invalid Test** (Baseline Range greater than 10.0 Pa)

## Section B

---

If Using  
TEC Software:  
(PR/FL Mode)

_____
-------

Nominal  
Building  
Pressure (Pa)

_____
-------

Nominal Fan  
Flow  
(CFM)

_____
-------

Fan  
Configuration

If Not Using  
Software:  
(PR/FL@50 Mode)

_____
-------

Induced  
Building  
Pressure (Pa)

_____
-------

Nominal  
CFM50

_____
-------

Fan  
Configuration

## Section C

---

_____
-------

Indoor Temp (F):

_____
-------

Outdoor Temp (F):

_____
-------

Site Elevation (ft)

Blower Door Fan

- Model: \_\_\_\_\_
- Serial Number: \_\_\_\_\_

Digital Gauge

- Model: \_\_\_\_\_
- Serial Number: \_\_\_\_\_

## **If Not Using Software:**

You may need to make corrections to your **Nominal CFM50** reading:

- If the site altitude is greater than 5,000 feet, use the **Altitude Correction Factor**.
- If the difference between the indoor outdoor temperature is greater than 30 degrees (F), use the **Temperature Correction Factor**.

**Corrected CFM50 = Nominal CFM50 x Altitude Correction Factor x Temperature Correction Factor**, where

**Altitude Correction Factor = 1 + (0.000006 x altitude (ft))**

**Temperature Correction Factor = value in Table 802.1 below.**

**Table 802.1 Temperature Correction Factors for Pressurization and Depressurization Testing- Calculated according to ASTM E779-10**

		Correction Factors for Pressurization Testing									Correction Factors for Depressurization Testing									
		INSIDE TEMPERATURE (F)									INSIDE TEMPERATURE (F)									
		50	55	60	65	70	75	80	85	90	50	55	60	65	70	75	80	85	90	
OUTSIDE TEMP (F)	-20	1.062	1.072	1.081	1.090	1.099	1.108	1.117	1.127	1.136	-20	0.865	0.861	0.857	0.853	0.849	0.845	0.841	0.837	0.833
	-15	1.056	1.066	1.075	1.084	1.093	1.102	1.111	1.120	1.129	-15	0.874	0.870	0.866	0.862	0.858	0.854	0.850	0.846	0.842
	-10	1.051	1.060	1.069	1.078	1.087	1.096	1.105	1.114	1.123	-10	0.883	0.879	0.874	0.870	0.866	0.862	0.858	0.854	0.850
	-5	1.045	1.054	1.063	1.072	1.081	1.090	1.099	1.108	1.117	-5	0.892	0.887	0.883	0.879	0.875	0.871	0.867	0.863	0.859
	0	1.039	1.048	1.057	1.066	1.075	1.084	1.093	1.102	1.111	0	0.900	0.896	0.892	0.887	0.883	0.879	0.875	0.871	0.867
	5	1.033	1.042	1.051	1.060	1.069	1.078	1.087	1.096	1.105	5	0.909	0.905	0.900	0.896	0.892	0.888	0.883	0.879	0.875
	10	1.028	1.037	1.046	1.055	1.064	1.072	1.081	1.090	1.099	10	0.918	0.913	0.909	0.905	0.900	0.896	0.892	0.888	0.884
	15	1.023	1.031	1.040	1.049	1.058	1.067	1.076	1.084	1.093	15	0.927	0.922	0.918	0.913	0.909	0.905	0.900	0.896	0.892
	20	1.017	1.026	1.035	1.044	1.052	1.061	1.070	1.079	1.087	20	0.935	0.931	0.926	0.922	0.917	0.913	0.909	0.905	0.900
	25	1.012	1.021	1.029	1.038	1.047	1.056	1.064	1.073	1.082	25	0.944	0.939	0.935	0.930	0.926	0.922	0.917	0.913	0.909
	30	1.007	1.015	1.024	1.033	1.041	1.050	1.059	1.067	1.076	30	0.952	0.948	0.943	0.939	0.934	0.930	0.926	0.921	0.917
	35	1.002	1.010	1.019	1.028	1.036	1.045	1.054	1.062	1.071	35	0.961	0.956	0.952	0.947	0.943	0.938	0.934	0.930	0.925
	40	0.997	1.005	1.014	1.023	1.031	1.040	1.048	1.057	1.065	40	0.970	0.965	0.960	0.956	0.951	0.947	0.942	0.938	0.934
	45	0.992	1.000	1.009	1.017	1.026	1.035	1.043	1.051	1.060	45	0.978	0.974	0.969	0.964	0.960	0.955	0.951	0.946	0.942
	50	0.987	0.995	1.004	1.012	1.021	1.029	1.038	1.046	1.055	50	0.987	0.982	0.977	0.973	0.968	0.963	0.959	0.955	0.950
	55	0.982	0.990	0.999	1.008	1.016	1.024	1.033	1.041	1.050	55	0.995	0.990	0.986	0.981	0.976	0.972	0.967	0.963	0.958
	60	0.977	0.986	0.994	1.003	1.011	1.019	1.028	1.036	1.045	60	1.004	0.999	0.994	0.989	0.985	0.980	0.976	0.971	0.967
	65	0.973	0.981	0.989	0.998	1.006	1.015	1.023	1.031	1.040	65	1.012	1.008	1.003	0.998	0.993	0.988	0.984	0.979	0.975
	70	0.968	0.976	0.985	0.993	1.001	1.010	1.018	1.026	1.035	70	1.021	1.016	1.011	1.006	1.001	0.997	0.992	0.988	0.983
	75	0.963	0.972	0.980	0.988	0.997	1.005	1.013	1.022	1.030	75	1.029	1.024	1.019	1.015	1.010	1.005	1.000	0.996	0.991
	80	0.959	0.967	0.976	0.984	0.992	1.000	1.009	1.017	1.025	80	1.038	1.033	1.028	1.023	1.018	1.013	1.009	1.004	0.999
	85	0.955	0.963	0.971	0.979	0.988	0.996	1.004	1.012	1.020	85	1.046	1.041	1.036	1.031	1.026	1.022	1.017	1.012	1.008
	90	0.950	0.958	0.967	0.975	0.983	0.991	0.999	1.008	1.016	90	1.055	1.050	1.045	1.040	1.035	1.030	1.025	1.020	1.016
	95	0.946	0.954	0.962	0.970	0.979	0.987	0.995	1.003	1.011	95	1.063	1.058	1.053	1.048	1.043	1.038	1.033	1.028	1.024
	100	0.942	0.950	0.958	0.966	0.970	0.982	0.990	0.998	1.007	100	1.072	1.066	1.061	1.056	1.051	1.046	1.041	1.037	1.032
	105	0.938	0.946	0.954	0.962	0.970	0.978	0.986	0.994	1.002	105	1.080	1.075	1.070	1.064	1.059	1.054	1.050	1.045	1.040
	110	0.933	0.942	0.950	0.952	0.966	0.974	0.982	0.990	0.998	110	1.088	1.083	1.078	1.073	1.068	1.063	1.058	1.053	1.048